

<http://www.glaciallight.com>


 7 F, No. 352, Sec. 2, Zhongshan Rd., Zhonghe Dist., New Taipei City,  
Taiwan, 235, R.O.C.

 Operator  
Telephone +886 2 2244-1227  
Fax +886 2 2244-1228  
e-Mail [sales@GlacialLight.com](mailto:sales@GlacialLight.com)

## GlacialLight GL-PL0606-V2-CW-5700K-110D / Luminaire Data Sheet

### Luminous emittance 1:

See our luminaire catalog for an image of the luminaire.



Luminaire classification according to CIE: 100  
CIE flux code: 48 80 96 100 110

### Luminous emittance 1:

Glare Evaluation According to UGR										
ρ Ceiling	70	70	50	50	30	70	70	50	50	30
ρ Walls	50	30	50	30	30	50	30	50	30	30
ρ Floor	20	20	20	20	20	20	20	20	20	20
Room Size X Y	Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17.4	18.7	17.7	19.0	19.2	16.9	18.2	17.2	18.5
	3H	19.0	20.2	19.3	20.4	20.7	18.3	19.4	18.6	19.7
	4H	19.6	20.7	19.9	21.0	21.3	18.7	19.8	19.1	20.1
	6H	20.1	21.1	20.4	21.4	21.7	19.0	20.0	19.3	20.3
	8H	20.2	21.2	20.6	21.5	21.8	19.1	20.1	19.4	20.4
4H	12H	20.3	21.3	20.7	21.6	21.9	19.1	20.0	19.4	20.3
	2H	18.0	19.1	18.3	19.4	19.7	17.6	18.7	17.9	19.0
	3H	19.7	20.7	20.1	21.0	21.3	19.1	20.0	19.5	20.4
	4H	20.4	21.3	20.8	21.6	22.0	19.7	20.5	20.1	20.9
	6H	21.0	21.7	21.4	22.1	22.5	20.0	20.8	20.5	21.1
8H	8H	21.2	21.9	21.7	22.3	22.7	20.1	20.8	20.6	21.2
	12H	21.4	22.0	21.8	22.4	22.8	20.2	20.8	20.6	21.2
	4H	20.6	21.3	21.1	21.7	22.1	19.9	20.6	20.4	21.0
	6H	21.3	21.9	21.8	22.3	22.7	20.4	21.0	20.9	21.4
	8H	21.6	22.1	22.1	22.5	23.0	20.6	21.0	21.0	21.5
12H	12H	21.8	22.2	22.3	22.7	23.2	20.6	21.0	21.1	21.5
	4H	20.6	21.2	21.1	21.6	22.1	20.0	20.6	20.4	21.0
	6H	21.3	21.8	21.8	22.3	22.7	20.5	20.9	20.9	21.4
8H	21.6	22.0	22.1	22.5	23.0	20.6	21.0	21.1	21.5	
Variation of the observer position for the luminaire distances S										
S = 1.0H		+0.1 / -0.1					+0.1 / -0.2			
S = 1.5H		+0.2 / -0.3					+0.3 / -0.5			
S = 2.0H		+0.5 / -0.6					+0.5 / -0.9			
Standard table		BK06					BK05			
Correction		4.9					3.5			
Summand										
Corrected Glare Indices referring to 3950lm Total Luminous Flux										


<http://www.glaciallight.com>

7 F, No. 352, Sec. 2, Zhongshan Rd., Zhonghe Dist., New Taipei City,  
Taiwan, 235, R.O.C.

Operator  
Telephone +886 2 2244-1227  
Fax +886 2 2244-1228  
e-Mail [sales@GlacialLight.com](mailto:sales@GlacialLight.com)

## GlacialLight GL-PL0606-V2-CW-5700K-110D / LDC (Polar)

Luminaire: GlacialLight GL-PL0606-V2-CW-5700K-110D  
Lamps: 1 x Panel Light (GL-PL0606-V2)



<http://www.glaciallight.com>


7 F, No. 352, Sec. 2, Zhongshan Rd., Zhonghe Dist., New Taipei City,  
Taiwan, 235, R.O.C.

Operator  
Telephone +886 2 2244-1227  
Fax +886 2 2244-1228  
e-Mail [sales@GlacialLight.com](mailto:sales@GlacialLight.com)

## GlacialLight GL-PL0606-V2-CW-5700K-110D / LDC (Linear)

Luminaire: GlacialLight GL-PL0606-V2-CW-5700K-110D

Lamps: 1 x Panel Light (GL-PL0606-V2)



<http://www.glaciallight.com>

 7 F, No. 352, Sec. 2, Zhongshan Rd., Zhonghe Dist., New Taipei City,  
 Taiwan, 235, R.O.C.

 Operator  
 Telephone +886 2 2244-1227  
 Fax +886 2 2244-1228  
 e-Mail [sales@GlacialLight.com](mailto:sales@GlacialLight.com)

## GlacialLight GL-PL0606-V2-CW-5700K-110D / UGR-Table

Luminaire: GlacialLight GL-PL0606-V2-CW-5700K-110D

Lamps: 1 x Panel Light (GL-PL0606-V2)

Glare Evaluation According to UGR											
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room Size X            Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	17.4	18.7	17.7	19.0	19.2	16.9	18.2	17.2	18.5	18.7
	3H	19.0	20.2	19.3	20.4	20.7	18.3	19.4	18.6	19.7	20.0
	4H	19.6	20.7	19.9	21.0	21.3	18.7	19.8	19.1	20.1	20.4
	6H	20.1	21.1	20.4	21.4	21.7	19.0	20.0	19.3	20.3	20.6
	8H	20.2	21.2	20.6	21.5	21.8	19.1	20.1	19.4	20.4	20.7
	12H	20.3	21.3	20.7	21.6	21.9	19.1	20.0	19.4	20.3	20.7
4H	2H	18.0	19.1	18.3	19.4	19.7	17.6	18.7	17.9	19.0	19.3
	3H	19.7	20.7	20.1	21.0	21.3	19.1	20.0	19.5	20.4	20.7
	4H	20.4	21.3	20.8	21.6	22.0	19.7	20.5	20.1	20.9	21.2
	6H	21.0	21.7	21.4	22.1	22.5	20.0	20.8	20.5	21.1	21.5
	8H	21.2	21.9	21.7	22.3	22.7	20.1	20.8	20.6	21.2	21.6
	12H	21.4	22.0	21.8	22.4	22.8	20.2	20.8	20.6	21.2	21.6
8H	4H	20.6	21.3	21.1	21.7	22.1	19.9	20.6	20.4	21.0	21.4
	6H	21.3	21.9	21.8	22.3	22.7	20.4	21.0	20.9	21.4	21.8
	8H	21.6	22.1	22.1	22.5	23.0	20.6	21.0	21.0	21.5	22.0
	12H	21.8	22.2	22.3	22.7	23.2	20.6	21.0	21.1	21.5	22.0
12H	4H	20.6	21.2	21.1	21.6	22.1	20.0	20.6	20.4	21.0	21.4
	6H	21.3	21.8	21.8	22.3	22.7	20.5	20.9	20.9	21.4	21.9
	8H	21.6	22.0	22.1	22.5	23.0	20.6	21.0	21.1	21.5	22.0
Variation of the observer position for the luminaire distances S											
S = 1.0H		+0.1 / -0.1					+0.1 / -0.2				
S = 1.5H		+0.2 / -0.3					+0.3 / -0.5				
S = 2.0H		+0.5 / -0.6					+0.5 / -0.9				
Standard table		BK06					BK05				
Correction Summand		4.9					3.5				
Corrected Glare Indices referring to 3950lm Total Luminous Flux											

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 0.25.

<http://www.glaciallight.com>

7 F, No. 352, Sec. 2, Zhongshan Rd., Zhonghe Dist., New Taipei City,  
Taiwan, 235, R.O.C.

Operator  
Telephone +886 2 2244-1227  
Fax +886 2 2244-1228  
e-Mail [sales@GlacialLight.com](mailto:sales@GlacialLight.com)

## GlacialLight GL-PL0606-V2-CW-5700K-110D / LDC Data Sheet

Luminaire: GlacialLight GL-  
PL0606-V2-CW-5700K-110D

Lamps: 1 x Panel Light (GL-  
PL0606-V2)

