

DEGREES OF PROTECTION PROVIDED BY ENCLOSURES PATTERN TEST REPORT

Test Standard : IEC/EN 60598-1 (2008)、IEC/EN 60529 (2001)

Date of Receipt : 2014 / 09 / 29

Test Date : 2014 / 09 / 29 ~ 2014 / 10 / 03

Result of determination this subclass type experiment : **PASS(IP65)**

1. Issue date for test report : 2014 / 10 / 03
2. Report No : 14092904
3. Total pages : 8
4. Test report without steel stamp is not valid, and shall not be reproduced except in full.
5. Test sample is not sampling by laboratory, test result relate only to the items tested.
6. Test report is not responsible for advertisement or promotion for products.

Approved Signatory:

Test Report

Information for test items

Applicant : GlacialTech Inc

Applicant address : 9Fl., No. 352, Sec. 2, Jung Shan Rd., Jung He City, Taipei,
Taiwan, 235, R.O.C

Manufacturer : GlacialTech Inc

Manufacturer address : 9Fl., No. 352, Sec. 2, Jung Shan Rd., Jung He City,
Taipei, Taiwan, 235, R.O.C

Product name : LED Bay Light

Model No. : GL-BL30XYZ

Uses the place : in door out door

Application test rank : IP65

-Following blank-

Test content

Standard chapter		Result of test	Determination
Temperature : 25.3 °C Humidity : 52.1 %RH			
IP6X	IEC/EN 60598-1 (sec.9) IEC/EN 60529 (sec.11.4) (sec.13.1) (sec.13.4) (sec.13.6)	No dust into the enclosure	PASS
IPX5	IEC/EN 60598-1 (sec.9) IEC/EN 60529 (sec.14.1) (sec.14.2.5) (sec.14.3)	No water into the enclosure, and was still normal the movement	PASS

-Following blank-

Photo of test items

The appearance of photo



The appearance of photo



Photo of test items

IP6X testing



IP6X after the test




Photo of test items

IPX5 testing



IPX5 after the test



Photo of test items

IPX5 after the test



-Following blank-

Equipment list and testing engineer for test

Item	Equipment No	Equipment	Manufacturer / Type / Series No
1	99S-04	Bears the dust testing machine class dust + Floating dust	TAICHY TECHNOLOGY LTD DT-1500CF
2	99S-07	Bears the rain water testing machine	TAICHY TECHNOLOGY LTD RT-IEC-IPX5.6
3	99S-10	IP test touch and access wire	Shanghai Haiyue Electric / DTPP-1.0/100
Testing engineers : Wei-Zhi Huang			

-Following blank-